

Feature	Mobility	Pass range	Total number of questions	Pass (1) / Fail (0)	Visual	Pass range	Total number of questions	Pass (1) / Fail (0)	Hearing	Pass range	Total number of questions	Pass (1) / Fail (0)	Neurodivergent	Pass range	Total number of questions	Pass (1) / Fail (0)	Allergy	Pass range	Total number of questions	Pass (1) / Fail (0)	
General	Accessibility information on website	yes	1	0	Accessibility information format	at least 2	1	0.5	Assistance for people with hearing impairments (hearing loop, sign language or video information with subtitles)	at least 2	1	0.5	Accessibility training	yes	1	0	Accessibility / allergy training	yes	1	0	
	Accessibility training	yes	1	0	Accessibility training	yes	1	0					Service animals policy	allow	1	1	Service animals policy	allow	1	1	
	Service animals policy	allow	1	1	Service animals policy	allow	1	1									Fragrance-free products for cleaning	use	1	1	
	Assistive equipment (mobility)	at least 1 (wheelchair)	1	1	Assistance for people with visual impairments	at least 2	1	0.5									Ventilation / air cleaning system	works properly	1	1	
																	Area is smoke-free	yes	1	1	
Parking	Parking space (number - out of total)	1 to 25 - 1 26 to 50 - 2 51 to 75 - 3 76 to 100 - 4 101 to 150 - 5 151 to 200 - 6 201 to 300 - 7 301 to 400 - 8 401 to 500 - 9 501 to 1000 - 2% of total	1	1	Parking space (number - out of total)	1 to 25 - 1 26 to 50 - 2 51 to 75 - 3 76 to 100 - 4 101 to 150 - 5 151 to 200 - 6 201 to 300 - 7 301 to 400 - 8 401 to 500 - 9 501 to 1000 - 2% of total	1	1	Parking space (number - out of total)	1 to 25 - 1 26 to 50 - 2 51 to 75 - 3 76 to 100 - 4 101 to 150 - 5 151 to 200 - 6 201 to 300 - 7 301 to 400 - 8 401 to 500 - 9 501 to 1000 - 2% of total	1	1	Parking space (number - out of total)	1 to 25 - 1 26 to 50 - 2 51 to 75 - 3 76 to 100 - 4 101 to 150 - 5 151 to 200 - 6 201 to 300 - 7 301 to 400 - 8 401 to 500 - 9 501 to 1000 - 2% of total	1	1					
	Parking space (width)	96 inches (2440 mm) and more	1	1	Access aisle (marking)	yes	1	1													
	Access aisle (width)	60 inches (1524 mm) and more	1	1	Curb ramp (contrast)	yes	1	1													
	Curb ramp (width)	36 inches (915 mm) and more	1	1																	
External routes	Clear width of the walking path	32 inches (813 mm) and more	1	1	Walking path	Stable, firm, slip-resistant	1	1					Walking path	Stable, firm, slip-resistant	1	1					

Feature	Mobility	Pass range	Total number of questions	Pass (1) / Fail (0)	Visual	Pass range	Total number of questions	Pass (1) / Fail (0)	Hearing	Pass range	Total number of questions	Pass (1) / Fail (0)	Neurodivergent	Pass range	Total number of questions	Pass (1) / Fail (0)	Allergy	Pass range	Total number of questions	Pass (1) / Fail (0)
	Walking path	Stable, firm, slip-resistant	1	1	Tripping hazard	No	1	0.5					Tripping hazard	No	1	0.5				
	Tripping hazard	No	1	0.5																
Entrance	Easy to identify	yes	1	1	Easy to identify	yes	1	1					Easy to identify	yes	1	1				
	Door (width)	32 inches (813 mm) and more	1	1	Door (contrasted)	yes	1	1					Door (contrasted)	yes	1	1				
	Door (opening force)	less than 40 N / automatic	1	1	Threshold	1/2 inches (13 mm) and lower	1	1					Threshold	1/2 inches (13 mm) and lower	1	1				
	Threshold	1/2 inches (13 mm) and lower	1	1																
Information desk	Information desk (height)	36 inches (915 mm) and less	1	1																
Seating area	Seating area (unobstructed approach)	yes	1	1	Seating area (unobstructed approach)	yes	1	1												
	Bench (height)	between 17 and 19 inches (430–485 mm)	1	1																
	Bench (depth)	20 to 24 inches (500–610 mm)	1	1																
Internal routes	Clear width of the walking path	32 inches (813 mm) and more	1	1	Signage (features)	at least 2	1	1					Signage (features)	at least 2	1	1				
	Floor surface	Stable, firm, slip-resistant	1	1	Signage (contrasted to background)	yes	1	1					Signage (contrasted to background)	yes	1	1				
	Tripping hazard	No	1	1	Signage (raised, Braille)	yes	1	0					Floor surface	Stable, firm, slip-resistant	1	1				
	Drinking fountains	suitable for both standing and seated users	1	1	Floor surface	Stable, firm, slip-resistant	1	1					Tripping hazard	No	1	1				
					Tripping hazard	No	1	1												
Lighting	Abrupt transition from light to dark.	no	1	1	Abrupt transition from light to dark.	no	1	1	Sufficient to facilitate sign language and lipreading	yes	1	1	Abrupt transition from light to dark.	no	1	1				

Feature	Mobility	Pass range	Total number of questions	Pass (1) / Fail (0)	Visual	Pass range	Total number of questions	Pass (1) / Fail (0)	Hearing	Pass range	Total number of questions	Pass (1) / Fail (0)	Neurodivergent	Pass range	Total number of questions	Pass (1) / Fail (0)	Allergy	Pass range	Total number of questions	Pass (1) / Fail (0)
	Interactive elements: height of the operable part	48 inches (1220 mm) and less	1	1																
TOTAL questions asked			47	42			32	26.5			3	2.5			25	22.5			6	4
%passed			89.36%				82.81%				83.33%				90.00%				66.67%	
Key features			12	12			7	5			2	1.5			7	6			3	3
%passed			100.00%				71.43%				75.00%				85.71%				100.00%	
GOLD BADGE THRESHOLD																				
TOTAL questions asked			37.6				25.6				2.4				20				4.8	
Key features			12				7				2				7				3	
DECISION			GOLD				SILVER				SILVER				SILVER				SILVER	